

NOTICE STANDBY GENERATOR INSTALLATIONS

NFPA 37 - SECTION 4.1.4 - ENGINES LOCATED OUTDOORS

Engines, and their weatherproof housings if provided, that are installed outdoors shall be located at least 1.5 meters (5 feet) from openings in walls and at least 1.5 meters (5 feet) from structures having combustible walls. A 5 foot minimum separation shall not be required where the following conditions exist:

- (1) The adjacent wall of the structure has a fire resistance rating of at least 1 hour.**
- (2) The weatherproof enclosure is constructed of noncombustible materials and it has been demonstrated that a fire within the enclosure will not ignite combustible materials outside the enclosure. (18" or separation per manufacturer's installation instructions)**

[Return to town site](#)